



**Bilco Brick**  
**Lancaster, TX**  
**Executive Summary**  
 Project No. 2601-03

Thirty-two types of concrete brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, maintenance cleaners suitable for the submitted samples were evaluated.

The laboratory report (2601-03 PTP Bilco Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

**Recommendations:**

Sample	New Construction Cleaning	Maintenance Cleaning
"Stardust" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner (1:2) or (1:3) OR Sure Klean® Vana Trol® (1:6) or (1:8) OR Sure Klean® 600 (1:6) or (1:8) OR Enviro Klean® Safety Klean (1:2) or (1:3)	2010 All Surface Cleaner (1:10) OR Klean 'N Release Cleaner (1:10)
"Winter Ash" Concrete Brick		
"Everest" Concrete Brick		
"Chestnut" Concrete Brick		
"Camel" Concrete Brick		
"Onyx" Concrete Brick		
"Gray Mist" Concrete Brick		
"Graystone" Concrete Brick		
"Wheaton" Concrete Brick		
"Dartford" Concrete Brick		
"Westfield" Concrete Brick		
"Sahara" Concrete Brick		
"Bristol" Concrete Brick		

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Bilco Brick**  
**Lancaster, TX**  
**Executive Summary**  
 Project No. 2601-03

**Recommendations: (cont.)**

Sample	New Construction Cleaning	Maintenance Cleaning
"Mountain Peak" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>1</sup> (1:3) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Sure Klean® 600 <sup>2</sup> (1:6) or <sup>2</sup> (1:8) OR Enviro Klean® Safety Klean <sup>2</sup> (1:2) or <sup>1</sup> (1:3)	2010 All Surface Cleaner (1:10) OR Klean 'N Release Cleaner (1:10)
"Frost" Concrete Brick		
"Scottsdale" Concrete Brick		
"Phoenix" Concrete Brick		
"Dune" Concrete Brick		
"Adobe" Concrete Brick		
"Eclipse" Concrete Brick		
"Williamsburg" Concrete Brick		
"Edinburgh" Concrete Brick		
"Bilco Gray" Concrete Brick		
"Caribbean Blue" Concrete Brick		
"Pinehurst" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner <sup>1</sup> (1:2) or <sup>1</sup> (1:3) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Sure Klean® 600 <sup>2</sup> (1:6) or <sup>2</sup> (1:8) OR Enviro Klean® Safety Klean <sup>2</sup> (1:2) or <sup>2</sup> (1:3)	

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



**Bilco Brick**  
**Lancaster, TX**  
**Executive Summary**  
 Project No. 2601-03

**Recommendations: (cont.)**

Sample	New Construction Cleaning	Maintenance Cleaning
"Rhodes" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>1</sup> (1:3) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Sure Klean® 600 <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Enviro Klean® Safety Klean <sup>2</sup> (1:2) or <sup>1</sup> (1:3)	
"Majestic" Concrete Brick		
"Gettysburg" Concrete Brick		
"Georgetown" Concrete Brick		
"Lime Green" Concrete Brick		
"Longhorn Orange" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>1</sup> (1:3) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Sure Klean® 600 <sup>2</sup> (1:6) or <sup>1</sup> (1:8) OR Enviro Klean® Safety Klean <sup>2</sup> (1:2) or <sup>2</sup> (1:3)	2010 All Surface Cleaner (1:10) OR Klean 'N Release Cleaner (1:10)
"Mustard Yellow" Concrete Brick	Sure Klean® Light Duty Concrete Cleaner <sup>2</sup> (1:2) or <sup>1</sup> (1:3) OR Sure Klean® Vana Trol® <sup>2</sup> (1:6) or <sup>2</sup> (1:8) OR Sure Klean® 600 <sup>2</sup> (1:6) or <sup>2</sup> (1:8) OR Enviro Klean® Safety Klean <sup>2</sup> (1:2) or <sup>2</sup> (1:3)	

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.